

2017

## Fire Log Texas Lutheran University

Date	Location on campus	Actual Fire	False Alarm	Time occurred	Damage	Injuries	Fatalities	Building Situation
11/01/17	Clifton Hall	no	x	11:15 PM	no	no	no	detector in room 106
10/10/17	Centennial Hall	no		7:23 PM	no	no	no	Plugged in item overheated
09/17/17	Clifton Hall	no	x	11:05 AM	no	no	no	Steam from shower
04/12/17	Clifton Hall	no	x	4:45 AM	no	no	no	Student vaping in room
03/31/17	Clifton Hall	no	x	1:15 PM	no	no	no	Fire panel
03/21/17	Clifton Hall	no	x	11:16 PM	no	no	no	Fire panel
02/20/17	Hahn Hall	no	x	7:51 AM	no	no	no	Fire panel
02/20/17	Hahn Hall	no	x	8:50 AM	no	no	no	Fire panel
01/11/17	Hahn Hall	no	x	4:00 AM	no	no	no	Fire panel
01/10/17	Hahn Hall	no	x	11:34 AM	no	no	no	Fire panel
11/11/17	Clifton Hall	no	x	10:44 AM	no	no	no	detector in room 220
11/11/17	Clifton Hall	no	x	11:04 AM	no	no	no	Fire panel